



STATE OF WEST VIRGINIA
DEPARTMENT OF HEALTH
BUREAU FOR PUBLIC HEALTH
Commissioner's Office

Sherri A. Young, DO, MBA, FAAFP
Cabinet Secretary

Justin J. Davis
Interim Commissioner

August 1, 2024

Mr. David Simon
Valencia Pipe Company, Inc.
28305 Livingston Ave.
Valencia, CA 91350

Dear Mr. Simon:

Our Department has reviewed your submission for approval of the Valencia Pipe Company septic tanks listed below:

Valencia Pipe Company	LIQUID CAPACITY
Model 87-41718	1000 Gallons, 1 Comp
Model 87-41720	1000 Gallons, 2 Comp
Model 87-41758	1500 Gallons, 1 Comp
Model 87-41760	1500 Gallons, 2 Comp

The above tanks are approved for use in West Virginia under circumstances where appropriate, based on size, design, and certified purpose. None of the above listed tanks are certified for use as pump tanks or holding tanks.

Inlets and outlet holes shall be installed in the appropriate locations prior to shipping tanks into West Virginia. Complete and specific backfill instructions shall be included with each tank.

Paragraph 6.4.g.10. of WV64CSR47 requires that "All tanks shall have a four (4) inch gas tight inspection port that extends to the surface...". Valencia Pipe Company has indicated that an appropriate penetration point for the 4" pipe does not exist on the tank bodies and that drilling the lids is not appropriate. Therefore at least one riser must be brought to the surface on all installations. Distributors shall remind purchasers of this requirement and offer suitable risers and lids for each unit, along with a method of watertight attachment, with instructions.

Information indicating the manufacturer's name, the liquid capacity, and the date of manufacture as required by paragraph 6.4.g.9. of WV64CSR47 shall appear as embossed lettering on the exterior surface of the tank body.



Valencia Pipe Company, Inc.


August 1, 2024

Page 2

If tanks are not NSF approved for use as cisterns this should be placarded on the tank or be mentioned prominently in the accompanying literature, to include the installation and backfill instructions.

The approval of the above-named units does not constitute an endorsement of your product. The Public Health Sanitation Division reserves the right to rescind these approvals should conditions warrant. Should you have any questions please feel free to contact me at (304) 352-5009.

Sincerely,

A handwritten signature in blue ink, reading "Rick Hertges", with a horizontal line extending from the end of the signature.

Rick Hertges, R.S., CPSS
Program Manager
Onsite Sewage Program